




COLD WATER LAYOUT

SCALE 1:150METERS



PLUMBING NOTES

- ALL MATERIALS, FIXTURES & EQUIPMENT TO BE USED IN THE PLUMBING INSTALLATION SHALL BE NEW, OF THE APPROVED TYPE & SIZE AS TO ITS INTENDED USAGE.
- ALL INSTALLATION SHALL BE IN CONFORMANCE WITH THE PLUMBING CODE OF THE PHILIPPINES, ITS RULES & REGULATIONS.
- DRAINAGE PIPING SHALL BE PROVIDED WITH APPROVED INLET FITTINGS FOR FIXTURE CONNECTIONS, CORRECTLY LOCATED ACCORDING TO THE SIZE & TYPE OF FIXTURE PROPOSED TO BE
- CHANGE IN DIRECTION OF DRAINAGE PIPING SHALL BE MADE WITH APPROPRIATE USE OF APPROVED FITTINGS & SHALL BE OF THE ANGLES REPRESENTED BY A 1/16 BEND, 1/8 BEND, 1/6 BEND OR OTHER APPROVED FITTINGS OR EQUIVALENT SWEEP.
- PROVIDE CLEAN OUT FOR EACH CHANGE IN DIRECTION IF THE TOTAL AGGREGATE CHANGE EXCEEDS 135 DEGREES.
- EACH CLEAN OUT SHALL BE INSTALLED SO THAT IT OPENS IN A DIRECTION OPPOSITE TO THE FLOW OF SOIL OR WASTE OR AT RIGHT ANGLES THERETO. ADDITIONAL CLEAN OUTS SHALL BE INSTALLED AT INTERVALS NOT TO EXCEED 100 FT (30.5 m.) IN STRAIGHT RUNS.
- HORIZONTAL DRAINAGE PIPING SHALL RUN IN PRACTICAL ALIGNMENT & A UNIFORM SLOPE OF NOT LESS THAN 1/4 OF AN INCH PER FOOT (20.8 mm/mt.) OR 2% TOWARD THE POINT OF DISPOSAL.
- UNLESS PROHIBITED BY STRUCTURAL CONDITIONS, EACH VENT SHALL RISE VERTICALLY TO A POINT NOT LESS THAN 6" (152.4 mm) ABOVE THE FLOOD LEVEL RIM OF THE FIXTURE SERVED BEFORE OFFSETTING HORIZONTALLY.
- EACH VENT PIPE OR STACK SHALL EXTEND THROUGH ITS FLASHING & SHALL TERMINATE VERTICALLY NOT LESS THAN 6" (152.4 mm) ABOVE THE ROOF & ONE FOOT (0.30 m.) FROM ANY VERTICAL SURFACE.
- PIPING SHALL BE LAID ON A FIRM BED THROUGHOUT ITS ENTIRE LENGTH. IF ANY SUCH PIPING IS LAID IN MADE OR FILLED GROUND, IT SHALL BE LAID ON A BED OF APPROVED MATERIALS & SHALL BE ADEQUATELY SUPPORTED.

SCREENHOUSE



S.A. 9356 - Art. 3, Section 20
DRAWINGS AND SPECIFICATIONS DULY SIGNED, STAMPED OR SEALED, AS INSTRUMENTS OF SERVICE ARE THE INTELLECTUAL PROPERTIES AND DOCUMENTS OF THE ARCHITECT, WHETHER THE SUBJECT FOR WHICH THEY ARE MADE IS EXECUTED OR NOT. IT SHALL BE UNLAWFUL FOR ANY PERSON, WITHOUT THE CONSENT OF THE ARCHITECT OR AUTHOR OF SAID DOCUMENTS, TO DUPLICATE OR TO MAKE COPIES OF SAID DOCUMENTS FOR USE IN THE REPERITION OF AND FOR OTHER PROJECTS OR BUILDINGS, WHETHER EXECUTED PARTLY OR IN WHOLE.

PROJECT: CONSTRUCTION HEADHOUSE AND SCREENHOUSE FOR ONE RICE PH. OF PHILRICE
PHILRICE - CES
MALIGAYA, SCIENCE CITY OF MUÑOZ, NUEVA ECJA

PRODUCED BY: PHYSICAL PLANT DIVISION
INFRASTRUCTURE UNIT
PHILRICE-CES
SCIENCE CITY OF MUÑOZ, NUEVA ECJA

PREPARE BY: AR. REYNALDO DC. ABAD
CONSULTING MASTER PLUMBER

END USER: DR. GENARO S. RILLON
CHIEF SRS CPD, PHILRICE-CES

RECOMMENDING APPROVAL: ABNER T. MONTECALVO
DED FOR ASF
PHILRICE-CES

APPROVED: JOHN C. DE LEON
EXECUTIVE DIRECTOR
PHILRICE - CES

DESIGN BY : RBB	P1	
DATE:		
CADD BY: DG & LG	07	17
DATE:		
CHECKED BY:		